

# CONDENSER SETTINGS AND GLIDE

Technical Bulletin

---

Refrigerant blends with glide (R-400 series)

Bulletin#: 12.0 rev 0.0

Application: Refrigeration

---

## BACKGROUND


Zeotropic refrigerant blends exhibit a temperature glide (glide) during phase change in the condenser and evaporator. In other words, the temperature changes as the refrigerant condenses or evaporates at a constant pressure\*. 4.09f01 and higher versions of Emerson's E2 and E2E controllers have multiple selections for refrigerants with glide. For example, when setting up a suction group for R-448A the controller has options for "R-448A Bubble (Liq)", "R-448A Dew (Vapor)", and "R-448A Mid-point". These different options are also available when setting up a condenser with differential control.

## QUESTION

What are the implications of different refrigerant selections and what settings are recommended?

## RESOLUTION

A review of the information below will allow the settings to be understood and setup properly. The screen shot shows the selection of the different R-448A "refrigerant types".



The controller has the option to set the suction group value by suction temperature or suction pressure.

## SETTING UP SUCTION GROUP USING TEMPERATURE

We first need to know the design temperature. This is the value given by the fixture manufacturer. It can also be obtained by looking at the system refrigeration schedule.

In this example we will use a value of 20°F for the system suction temperature.

This is the temperature we want to maintain by the evaporator coil. As a reference here are tables with saturated pressure and temperature values for R-448A.

Pressure (psig)	Bubble (Liq) °F	Mid-Point °F	Dew (vapor) °F
51	14.8	20	25

Table 1: temperatures at bubble, avg, dew locations at constant pressure values

The air that passes over the evaporator coil will encounter some areas with the bubble temp, the dew temp, and all the temperatures in-between. Because of this the average temperature that the air encounters is the average (mid-point) of the bubble and dew temperatures. Due to this, the mid-point temperature is the easiest value to use. If the bubble or dew refrigerant is selected the temperature setting will need to be adjusted to keep the 20° F coil. Referring to the table 1 for the settings for an effective 20°F evaporator temperature.

Refrigerant setting	Temperature Setting (°F)
R-448A Mid-point	20
R-448A Bubble (Liq)	14.8
R-448A Dew (Vapor)	25.2

### Recommendation:

For simplicity Honeywell recommends to always use mid-point. The mid-point is referred to as "Average" in Honeywell PT charts.

## SETTING UP SUCTION GROUP USING PRESSURE

If pressure is selected as the control method a different process is used. For a 20°F evaporator we would select “R-448A mid-point” and the pressure corresponding to an average 20°F coil. In table below above we can see this would be 51psig. If the bubble or dew refrigerant is selected the system will continue to run at the correct temperature as long as the pressure setting remains at 51psig. However, using the bubble or dew as the selected refrigerant will result in the temperature showing the dewpoint or bubble point temperature and not the effective condensing temperature.


Refrigerant	Pressure setting (psig)	Condensing Temperature on screen (°F)
R-448A Mid-point	51	20
R-448A Bubble (Liq)	51	14.8
R-448A Dew (Vapor)	51	25.2

### Recommendation:

Use mid-point and a pressure setting that corresponds to the mid-point evaporator temperature.

## SETTING UP CONDENSER CONTROL WITH DIFFERENTIAL CONTROL

The screen for condenser TD control allows for selecting average, bubble, or dew for the refrigerant



As a reference here is a table with saturated pressure and temperature values for an effective 90°F condenser:

Pressure	Bubble (Liq) (°F)	Mid-point (°F)	Dew (vapor) (°F)
197	85.6	90	94.6

Table 2: condensing pressure and temperatures – R-448A

TD control works by maintaining a temperature difference between the ambient temperature and the saturated temperature of the condenser. For example, if we want to maintain a 10°F TD across the coil and it is 80°F outside we would maintain 90°F. If mid-point is selected in the condenser screen we would simply select 10°F as the setpoint. However, if dew or bubble are selected the set-point would need to change to compensate.

Refrigerant	TD setting (°F)	Condenser temperature setting (°F)	Average condenser temperature (°F)
R-448A Mid-point	10	90	90
R-448A Bubble (Liq)	4.4	84.4	90
R-448A Dew (Vapor)	14.6	94.6	90

**Recommendation:**

Use the midpoint and a TD at least as high as the condenser design TD and no smaller than 10°F.

\*Some minor pressure drop due to friction may occur.



Although Honeywell International Inc. believes that the information contained herein is accurate and reliable, it is presented without guarantee or responsibility of any kind and does not constitute any representation or warranty of Honeywell International Inc., either expressed or implied. A number of factors may affect the performance of any products used in conjunction with user's materials, such as other raw materials, application, formulation, environmental factors and manufacturing conditions among others, all of which must be taken into account by the user in producing or using the products. The user should not assume that all necessary data for the proper evaluation these products are contained herein. Information provided herein does not relieve the user from the responsibility of carrying out its own tests and experiments, and the user assumes all risks and liabilities (including, but not limited to, risks relating to results, patent infringement, regulatory compliance and health, safety and environment) related to the use of the products and/or information contained herein.

**For more information:**  
[www.honeywell-refrigerants.com](http://www.honeywell-refrigerants.com)

**Honeywell Refrigerants**  
 115 Tabor Road  
 Morris Plains, NJ 07950  
 Phone: 1-800-631-8138

Solstice is a registered trademark of Honeywell International

4730 FP | November 2019  
 ©2019 Honeywell International Inc. All rights reserved

