

Refrigerant Charge Calculation

Technical Bulletin

Products: Solstice® N40 (R-448A), Solstice N13 (R-450A),

Genetron Performax® LT (R-407F)

Bulletin#: 09 rev 0.0

Application: Refrigeration



Background

When designing refrigeration systems for supermarkets or other large commercial projects it is helpful to include the expected refrigerant charge in the construction documents. This allows for accurate competitive bidding and assurance of ample refrigerant during startup.

Problem

Calculating refrigerant charge by experience or rule-of-thumb can be inaccurate.

Resolution

A series of charts have been developed to assist in calculating system charge.

The total charge will be the sum of the refrigerant in the piping to the fixtures (circuits), the receiver charge, the condenser charge and the evaporator charges. Table 5 can be used to combine all charges for a total charge.

Solstice N40 (R-448A) charges per 100ft of piping
Charge Calculation Table 1

Line Size OD (inches)	Weight per 100ft of piping (lbs)					
	Liquid Line	Discharge/ Hot Gas Defrost	Suction Line @ Select Evaporator Temperature			
			-25°F	-15°F	+15°F	+25°F
3/8	3.5	0.20	0.02	0.03	0.06	0.07
1/2	6.6	0.37	0.05	0.06	0.11	0.13
5/8	10.6	0.59	0.07	0.09	0.17	0.21
3/4	15.9	0.88	0.11	0.14	0.25	0.31
7/8	22.0	1.2	0.15	0.19	0.35	0.43
1-1/8	37.6	2.1	0.26	0.33	0.60	0.73
1-3/8	57.2	3.2	0.40	0.50	0.92	1.1
1-5/8	81.0	4.5	0.57	0.70	1.3	1.6
2-1/8	140.9	7.8	0.99	1.2	2.3	2.7
2-5/8	217.3	12.1	1.5	1.9	3.5	4.2
3-1/8	310.2	17.2	2.2	2.7	5.0	6.0
3-5/8	419.6	23.3	2.9	3.6	6.7	8.1
4-1/8	543.2	30.2	3.8	4.7	8.7	10.5

Conditions: 105°F condensing, 5°F sub cooling, 0°F evaporator for discharge calculations

Condenser Refrigerant Charge

Condensers have varying charges based on manufacturer, model, and the condenser. Manufacturers' data sheets will supply charge values based on the condenser selected.

Note:

A condenser can also have up to a four times greater charge if holdback valves are used for winter head pressure control.

Evaporator Charges

Evaporators will have varying charges based on fixture type, manufacturer, and model. Manufacturers' data sheets will supply charge values based on the equipment selected.

Solstice N13 (R-450A) charges per 100ft of piping
Charge Calculation Table 2

Line Size OD (inches)	Weight per 100ft of piping (lbs)			
	Liquid Line	Discharge	Suction Line @ Select Evaporator Temperature	
			+15°F	+25°F
3/8	3.8	0.14	0.03	0.04
1/2	7.1	0.26	0.06	0.07
5/8	11.4	0.41	0.09	0.11
3/4	17.1	0.62	0.14	0.17
7/8	23.8	0.86	0.19	0.23
1-1/8	40.5	1.5	0.32	0.40
1-3/8	61.7	2.2	0.49	0.60
1-5/8	87.3	3.2	0.69	0.85
2-1/8	151.9	5.5	1.2	1.5
2-5/8	234.2	8.5	1.9	2.3
3-1/8	334.3	12.1	2.6	3.3
3-5/8	452.2	16.3	3.6	4.4
4-1/8	585.4	21.1	4.6	5.7

Genetron LT (R-407F) charges per 100ft of piping
Charge Calculation Table 3

Line Size OD (inches)	Weight per 100ft of piping (lbs)					
	Liquid Line	Discharge/ Hot Gas Defrost	Suction Line @ Select Evaporator Temperature			
			-25°F	-15°F	+15°F	+25°F
3/8	3.6	0.19	0.02	0.03	0.05	0.07
1/2	6.7	0.35	0.04	0.05	0.10	0.12
5/8	10.8	0.56	0.07	0.09	0.16	0.20
3/4	16.1	0.83	0.10	0.13	0.24	0.30
7/8	22.4	1.15	0.14	0.18	0.34	0.41
1-1/8	38.2	1.97	0.25	0.31	0.58	0.70
1-3/8	58.2	2.99	0.38	0.47	0.88	1.1
1-5/8	82.4	4.24	0.53	0.67	1.2	1.5
2-1/8	143.3	7.37	0.92	1.2	2.2	2.6
2-5/8	221.0	11.37	1.4	1.8	3.3	4.0
3-1/8	315.5	16.23	2.0	2.6	4.8	5.8
3-5/8	426.8	21.95	2.8	3.5	6.5	7.8
4-1/8	552.5	28.41	3.6	4.5	8.4	10.1

Conditions: 105°F condensing, 5°F sub cooling, 0°F evaporator for discharge calculations

Receiver Charge:

If the receiver dimensions or volume is known, the charge can be calculated from Table 4.

For example:

An 18-inch diameter, 6 ft long receiver would have a volume of length (ft) x area (ft²).

Volume =
 (6ft) x (3.14 x 1.5ft² ÷ 4) = 10.6 ft³
 (end bell volume is considered negligible)
 With a common fill percentage of 30%,
 the total charge for R-448A will be:
 65.6 x 10.6 x 0.3 = 208 lb.

**Table 4
Receiver Charge**

Refrigerant	Refrigerant Density (lb/ft ³)	Receiver Volume* (ft ³)	Fill %** (in decimal i.e., 0.3)	Refrigerant Charge (lb)
Solstice N40 (R-448A)	(65.6	x _____	x _____)	= _____
Genetron Performax LT (R-407F)	(66.7	x _____	x _____)	= _____
Solstice N13 (R-450A)	(70.5	x _____	x _____)	= _____

* Receivers are rarely filled to full level. 30% full is a common level.
 **Receivers are typically sized at 80% of expected refrigerant charge.

Total Charge:

Use the table below to combine the charges to determine the total charge.

Item	Refrigerant Charges (lbs)				Sum
	Liquid	Suction	Discharge	Hot Gas	
Calculation ->	Value from chart x length in feet ÷ 100				
Circuit 1	_____ lbs	+ _____ lbs	+ _____ lbs	+ _____ lbs	=
Circuit 2	_____ lbs	+ _____ lbs	+ _____ lbs	+ _____ lbs	=
Circuit 2	_____ lbs	+ _____ lbs	+ _____ lbs	+ _____ lbs	=
Circuit 2	_____ lbs	+ _____ lbs	+ _____ lbs	+ _____ lbs	=
Circuit 2	_____ lbs	+ _____ lbs	+ _____ lbs	+ _____ lbs	=
Additional Circuits as needed					
				Condenser Charge	=
				Evaporator Charge	=
				Receiver Charge	=
				Sum:	=

For more information:
Technical Support Team
800-631-8138
www.honeywell-refrigerants.com

Honeywell Refrigerants
115 Tabor Road
Morris Plains, NJ 07950

Although Honeywell International Inc. believes that the information contained herein is accurate and reliable, it is presented without guarantee or responsibility of any kind and does not constitute any representation or warranty of Honeywell International Inc., either expressed or implied. A number of factors may affect the performance of any products used in conjunction with user's materials, such as other raw materials, application, formulation, environmental factors and manufacturing conditions among others, all of which must be taken into account by the user in producing or using the products. The user should not assume that all necessary data for the proper evaluation of these products are contained herein. Information provided herein does not relieve the user from the responsibility of carrying out its own tests and experiments, and the user assumes all risks and liabilities (including, but not limited to, risks relating to results, patent infringement, regulatory compliance and health, safety and environment) related to the use of the products and/or information contained herein.



Genetron and Solstice are registered trademarks of Honeywell International Inc.

2255 FP Ref v4 | January 2018
© 2018 Honeywell International Inc. All rights reserved.

Honeywell